

SPE 17445

Kern River Field Test of a Steam Quality Measurement Technique

by C.L. Redus,* D.M. Schoen,* S.F. Chien, and D. Hall,* Texaco Inc.

*SPE Members

Copyright 1988, Society of Petroleum Engineers

This paper was prepared for presentation at the SPE California Regional Meeting held in Long Beach, California, March 23-25, 1988.

This paper was selected for presentation by an SPE Program Committee following review of information contained in an abstract submitted by the author(s). Contents of the paper, as presented, have not been reviewed by the Society of Petroleum Engineers and are subject to correction by the author(s). The material, as presented, does not necessarily reflect any position of the Society of Petroleum Engineers, its officers, or members. Papers presented at SPE meetings are subject to publication review by Editorial Committees of the Society of Petroleum Engineers. Permission to copy is restricted to an abstract of not more than 300 words. Illustrations may not be copied. The abstract should contain conspicuous acknowledgment of where and by whom the paper is presented. Write Publications Manager, SPE, P.O. Box 833836, Richardson, TX 75083-3836. Telex, 730989 SPEDAL.

ABSTRACT

In large steamflood operations, there is a need to measure accurately the steam quality and mass flow rate at the injection wellhead. At Texaco's steamflood operation at the Kern River Field in Bakersfield, California, a novel technique which incorporates an orifice plate in series with a critical flow choke has been developed and tested in the field.

Results from field testing proved the technique to be a potentially viable, low-cost and reasonably accurate method with an accuracy of +/- 5 quality points for steam quality and +/- 32 BSPD-CWE [5.09 m³/day - CWE] for flow rate. The method was tested at steam qualities ranging from 15 to 88% and at mass flow rates ranging from 200 to 800 BSPD-CWE [32 to 121 m³/day - CWE]. Upstream pressures ranged from 300 to 700 psia [2068 to 4826 kPa].

INTRODUCTION

Why measure steam quality in large steamflood operations? In Texaco's Kern River Field steamflood, over 20,000 equivalent barrels per day [3180 m³/day] of oil are burned as fuel to provide wet steam for distribution throughout the field. The ability to measure steam quality and mass

References and illustrations at end of paper.

flow rate throughout the injection network could potentially reduce generator fuel requirements by optimizing the delivery of steam. Steam quality measurement would enable engineers to detect patterns with low heat injection rates at remote points in the field and correct them to boost recovery from these patterns. In addition, the ability to measure steam quality and mass flow rate at steam injection wells would dramatically improve our ability to predict bottom hole steam quality in an injection well. Improved model studies could increase our ability to optimize recovery from thermal reservoirs.

Because of the large number of steam injection wells in commercial steamfloods, it is important that a wellhead steam quality measurement device be low-cost and durable. For example, in the Kern River Field there are more than 1500 injectors.

Critical flow chokes are typically installed at steam injection wellheads to control steam injection rate. However, both steam quality and mass flow rate cannot be determined from this device alone. The addition of the orifice plate upstream of the critical flow choke provides a second device so that independent equations for mass flow rate through each of these devices can be solved simultaneously to determine an expression for steam quality. By taking advantage of the existing chokes, the addition of an orifice plate gives a

simple, practical way of determining steam quality.

This paper presents a field test of this simple technique at Texaco's Kern River Field.

THEORETICAL DEVELOPMENT

The use of the orifice plate in series with a critical flow choke provides a method of measurement for both steam quality and mass flow rate. Neither the orifice plate nor choke alone can be used to measure steam quality and mass flow rate. However, an expression for steam quality through both devices is obtained by solving an independent mass flow rate equation for each device - an equation for wet steam through the critical flow choke and an equation for wet steam through a sharp-edged orifice plate.

Choke Equation

The Napier¹ equation for critical flow through a choke modified for wet steam by King and Crocker² is

$$G = 2.057 \frac{P}{X^{0.5}}, \dots\dots\dots(1)$$

where G is the critical mass flux in the choke, P is the absolute pressure upstream of the choke and X is steam quality upstream of the choke. The units of all terms are defined in the Nomenclature. Converting this equation to yield steam mass flow rate in BSPD-CWE gives

$$W = 2.767 \frac{c^2 P}{X^{0.5}}, \dots\dots\dots(2)$$

where c is the choke bore diameter and W is the mass flow rate of wet steam. For this field test, the exponent on steam quality "b" and the constant "a" are considered to be empirical constants whose values are determined by the regression analysis of our field data i.e.,

$$W = a \frac{c^2 P}{X^b}, \dots\dots\dots(3)$$

Orifice Plate Equation

Equation (3) gives mass flow rate through the choke as a function of pressure and steam quality upstream of the choke. Likewise, mass flow rate through the orifice plate must be expressed as a function of the differential pressure drop across the orifice plate and steam quality. The James³ equation for the flow of wet steam through a sharp-edged orifice can be expressed as

$$W = \frac{24.65 C_o d^2 Y}{[1 - (d/D)^4]^{0.5}} \left(\frac{\phi}{X^{1.5}(v_g - v_f) + v_f} \right)^{0.5}, \dots\dots\dots(4)$$

In this equation, C_o is the discharge coefficient; d is the diameter of the orifice plate; Y is the vapor expansion factor; φ is the differential pressure; D is the inside diameter of the meter run; X is the steam quality; v_f and v_g are the specific volumes of saturated water and steam at the pressure upstream of the choke. For steam qualities greater than 10%, the specific volume of water is small relative to the specific volume of steam and can therefore be neglected. The specific volume of steam vapor at pressures between 100 and 1000 psia [689 and 6895 kPa] can be expressed as

$$v_g = \frac{C_1}{P^{C_2}}, \dots\dots\dots(5)$$

where:

C ₁	C ₂	P
376.204	0.9640	100-300
486.340	1.0009	300-700
783.514	1.0817	700-1000

Substituting equation (5) into equation (4) and assuming v_f is small relative to v_g gives

$$W = \frac{24.65 C_o d^2 Y}{C_1 [1 - (d/D)^4]^{0.5}} \left(\frac{\phi P^{C_2}}{X^{1.5}} \right)^{0.5}, \dots\dots\dots(6)$$

This equation expresses mass flow rate through an orifice for pressures between 100 and 1000 psia [689 and 6895 kPa] and steam qualities between 10% and 100%. We now have two algebraically simple expressions relating mass flow rate and steam quality through the choke, equation (3), and through the orifice plate, equation (6).

Simultaneous Solution

Substituting equation (3) into equation (6) and solving for the steam quality give expressions for steam quality and mass rate through the device as

$$X = \left(\frac{607.62 C_o^2 (d/c)^4 Y^2 \phi}{C_1 a^2 [1 - (d/D)^4] P^{2-C_2}} \right)^{1/1.5-2b}, \dots\dots\dots(7)$$

$$W = a \frac{c^2 P}{X^b}, \dots\dots\dots(8)$$

The value of C_o according to James³ is

$$C_o = 0.61, \dots\dots\dots(9)$$

however, in this test, C_o is considered as an empirical factor to be determined from the field data. The vapor expansion factor Y corrects for the compressibility of steam which adiabatically expands as it passes through the orifice plate. Determination of the vapor expansion factor Y is included in the Appendix.

DESCRIPTION OF FIELD TEST

Choke In Series With An Orifice Plate

Figure 1 shows a plan and elevation view of a meter run in a 2-inch, schedule 40, (2.067 inch ID [5.26 cm]) steam line from a dedicated 12 MMBtu/hr [3.5 MW] steam generator to an injection well. The meter run consisted of a 2-inch (2.067 inch ID [5.26 cm]) meter tube with inline straightening vanes upstream of a 1/8 - inch [0.318 cm] thick sharp-edged orifice plate. Orifice plates used during the test were 1-inch [2.54 cm], 1.25-inch [3.17 cm], and 1.50-inch [3.81 cm]. A critical flow choke assembly which incorporated flow beans with bore diameters from 21 to 44 64ths of an inch [0.831 to 1.74 cm] was located downstream of the flange connected orifice plate. Between the orifice plate and the choke, the absolute pressure was measured with a pressure transducer while the differential pressure across the orifice plate was measured with a differential pressure transducer. The positioning of the orifice plate and straightening vanes in the meter run were according to the A. G. A. piping installation code for a 2-inch meter run.

Test Range And Procedure

A total of 200 test points were measured covering steam mass flow rates from 200 to 800 BSPD-CWE [32 to 121 m³/day - CWE] and steam qualities from 15% to 88%. Choke beans were sized to achieve these design rates and qualities by assuming a 500 psia pressure upstream of the choke. Once the feedwater flow rate through the generator was established using a positive displacement pump, the fuel rate to the generator was adjusted to achieve a given steam quality. The steam quality from the generator was determined by measuring the mass flow rate of feedwater entering the generator with a turbine meter. From these measurements, the steam quality

being discharged from the generator was determined from orifice plate data.

From a known mass rate through the orifice plate, the James Equation (4) can be used to calculate the known steam quality, using an orifice discharge factor of 0.61, flowing from the generator. To validate this procedure, spot checks of steam quality were made using the comparative conductivity technique.

TEST DATA

A total 200 test points were actually taken. Of these 90 points were eliminated because of instability of the generator at the times these points were taken or because the data points collected were redundant. Instability of the steam generator was detected by large fluctuations in discharge pressure and feedwater rate. These fluctuations may have resulted from improper combustion in the generator, lack of dampening on the feedwater positive displacement pump, or unexpected low backpressure.

The remaining 110 data points are representative of data collected at stable conditions and are shown in Table 1. Data recorded for each test point were the steam pressure between the orifice plate and the choke, differential pressure across the orifice plate, feedwater volumetric flow rate, choke bean diameter, orifice plate diameter, and the measured steam quality.

DISCUSSION OF RESULTS

Using the data in Table 1, an exponential least squares analysis of equation (3) gave the following regression constants

$$a = 2.5253, \dots\dots\dots(10a)$$

and

$$b = 0.466. \dots\dots\dots(10b)$$

Solving equation (7) for the discharge coefficient C_o of the orifice plate for each test point in Table 1 using equations (10a) and (10b) gave an average discharge coefficient of

$$C_o = 0.60. \dots\dots\dots(11)$$

Therefore, the final regression equations for steam quality and mass flow rate are

$$X = \left(\frac{95.28 C_2^2 (d/c)^4 Y^2 \phi}{C_1 [1 - (d/D)^4] P^{2-C_2}} \right)^{1.7606}, \dots\dots\dots (12)$$

and

$$W = 2.5253 \frac{c^2 P}{X^{0.466}}, \dots\dots\dots (13)$$

where P is between 300 and 700 psia [2068 and 4826 kPa], and steam quality X is between 15% and 88%. Table 2 shows the measured steam quality and mass flow rate compared with the predicted values using the above equations for each test point. The average steam quality deviation was +/- 4.6 quality points or an average error of 12.6%. The average mass flow rate deviation was +/- 31.9 BSPD-CWE [5.07 m³/day - CWE] or an average error of 8.7%. Figures 2, 3, 4, 5, 6, and 7 show the measured versus predicted steam quality and steam mass flow rate for the test data grouped by common orifice plate size.

Figure 8 shows the measured steam quality and rate data as well as the correlation equations plotted in a general form for an arbitrary pressure, choke diameter, orifice size, and pipe diameter. The abscissa and ordinate coordinates of this plot were developed from equations (12) and (13). To use this plot to determine steam quality, the expression on the left ordinate must be evaluated from the geometry of the choke and orifice plate and the measured absolute and differential pressures. The steam quality is determined by the intersection of a horizontal line from this value and the steam quality curve. By evaluating the intersection of a vertical line through the predicted steam quality and flow rate curve, the value of the rate expression can be determined. The right ordinate expression can then be solved for the steam mass flow rate.

APPLICABILITY OF THE DEVICE

This device is applicable to steamflood operations in which critical flow chokes are used to control steam injection rate. By design, critical flow chokes spoil about 50% of the pressure upstream of the chokes. For shallow injection wells this does not present a problem because of the relatively low wellhead injection pressures. For deep wells, however, critical flow chokes are rarely used because the high wellhead pressures at injectors coupled with the chokes would require very high generator pressures.

Appropriate methods and techniques suitable for deep wells are under development at Texaco's E & P Technology Division.

CONCLUSIONS

- A low cost field oriented steam quality meter has been developed and field tested which utilizes an orifice plate upstream of a critical flow choke to determine both steam quality and mass flow rate. Given the geometry of the choke and orifice plate, the static pressure upstream of the choke, and differential pressure across the orifice plate, the meter outputs quality and rate.
- Test data (110 test points), taken from Texaco's Kern River Field, were used to determine empirical constants in equations for predicting steam quality and mass flow rate. Predicted steam quality differed from measured steam quality by +/- 4.6 quality points while steam mass flow rate differed by +/- 31.9 BSPD-CWE [5.07 m³/day - CWE].
- This device is applicable for measuring steam quality and mass flow rate at injection wells in which critical flow chokes are used. This device is not applicable for steam injection wells in deep reservoirs due to the high pressures required to overcome the 50% reduction through critical flow chokes.

NOMENCLATURE

- | | | |
|---------------------------------|---|--|
| a | = | Regression constant in equation (3) (dimensionless) |
| b | = | Regression constant in equation (3) (dimensionless) |
| c | = | Choke bore diameter (in.) |
| C ₁ , C ₂ | = | Constants in equation (5) (dimensionless) |
| C _o | = | Discharge coefficient of orifice plate (dimensionless) |
| d | = | Diameter of orifice plate (in.) |
| D | = | Inside diameter of meter run (in.) |
| G | = | Critical mass flux in choke (lbm/ft ² -sec) |
| P | = | Absolute pressure upstream of choke and downstream of orifice (psia) |

- r = Pressure ratio across orifice (dimensionless)
- W = Mass flow rate through orifice/choke (bspd-cwe)
- X = Steam quality upstream of choke (fraction)
- Y = Steam vapor expansion factor (dimensionless)
- ϕ = Differential pressure across the orifice (in. of water)
- v_l = Specific volume of saturated water at a pressure upstream of the orifice (ft³/lbm)
- v_g = Specific volume of saturated steam at a pressure upstream of the orifice (ft³/lbm)
- γ = Specific heat ratio (dimensionless)

ACKNOWLEDGMENTS

The authors thank Texaco Inc. for permission to publish this paper; Mr. M. Randall for providing extensive assistance in building the test facility and Mr. B. A. Littlefield and Mr. H. Q. Bui for coordination of data acquisition.

REFERENCES

1. Hawkins, G. A.: "Thermal Properties of Substances and Thermodynamics," Mark's Standard Handbook for Mech. Engr., Eighth Edition, pp 4.46-4.49.
2. King, R. C. and Crocker, S.: Piping Handbook, Section 3, McGraw-Hill, New York, 1967, pp3-59.
3. James, R.: "Metering of Steam-Water Two Phase Flow by Sharp Edged Orifices," Proceedings Inst. Mech. Engr., Vol. 180 pt. 1, no.23, 1965-1966, pp 549-566.

APPENDIX

Vapor Expansion Factor

The vapor expansion factor, Y, in equation (4) as given by James³ is

$$Y = \sqrt{r^{2/\gamma} \left(\frac{\gamma}{\gamma-1} \right) \left(\frac{1-r^{\gamma}}{1-r} \right) \left(\frac{1-(d/D)^4}{1-(d/D)^4 r^{2/\gamma}} \right)}, \dots (A-1)$$

where the pressure ratio across the orifice can be calculated as

$$r = \left(1 + \frac{\phi}{27.692P} \right)^{-1} \dots (A-2)$$

The specific heat ratio of steam used in equation (A-1) is

$$\gamma = 1.3 \dots (A-3)$$

TABLE 2
MEASURED VERSUS PREDICTED
STEAM QUALITIES AND FLOWRATE

TEST DATA					MEASURED VERSUS PREDICTED STEAM QUALITIES AND FLOWRATE						
No.	Pressure (psig)	Differential Pressure (in. w.c.)	Feedwater Rate (bwpd)	Bean Size (64ths in.)	Orifice Diameter (in.)	Steam Quality (fraction)	No.	Measured Steam Quality (%)	Predicted Steam Quality (%)	Measured Flowrate (Bspd-cwe)	Predicted Flowrate (Bspd-cwe)
1	450.4	34.3	215.5	21	1.00	0.2951	1	29.5	31.9	216	211
2	455.4	34.2	208.6	21	1.00	0.3113	2	31.1	31.2	209	215
3	522.1	45.4	187.2	21	1.00	0.4902	3	49.0	40.0	187	220
4	659.4	72.4	194.1	21	1.00	0.7622	4	76.2	59.5	194	231
5	333.7	56.5	297.0	26	1.00	0.2191	5	21.9	28.3	297	255
6	334.8	53.0	298.0	26	1.00	0.2080	6	20.8	25.4	298	269
7	508.3	110.4	299.2	26	1.00	0.4626	7	46.3	43.8	299	315
8	515.1	111.8	297.3	26	1.00	0.4755	8	47.5	43.8	297	319
9	629.4	164.0	304.0	26	1.00	0.6944	9	69.4	59.6	304	338
10	615.3	162.0	310.0	26	1.00	0.6591	10	65.9	60.6	310	328
11	660.7	190.7	304.9	26	1.00	0.7944	11	79.4	70.6	305	329
12	654.7	182.8	314.9	26	1.00	0.7328	12	73.3	67.9	315	334
13	315.8	89.0	571.8	30	1.00	0.2008	13	20.1	22.5	372	357
14	601.2	254.1	406.0	30	1.00	0.6059	14	60.6	50.8	406	462
15	611.9	258.7	406.0	30	1.00	0.6214	15	62.1	50.9	406	470
16	603.5	254.9	406.3	30	1.00	0.6083	16	60.8	50.8	406	464
17	687.0	324.9	415.2	30	1.00	0.7654	17	76.5	61.3	415	484
18	682.2	326.8	415.5	30	1.00	0.7638	18	76.4	62.6	416	477
19	679.1	325.9	416.6	30	1.00	0.7571	19	75.7	62.8	417	474
20	324.0	108.8	516.9	32	1.00	0.1493	20	14.9	22.0	508	472
21	510.4	257.9	508.2	32	1.00	0.3951	21	39.5	43.9	508	479
22	503.5	254.6	510.1	32	1.00	0.3853	22	38.5	43.9	510	472
23	370.8	184.3	598.8	35	1.00	0.1949	23	19.5	23.2	599	559
24	362.0	169.8	602.9	35	1.00	0.1781	24	17.8	21.1	603	570
25	490.4	341.0	589.8	35	1.00	0.3766	25	37.7	40.5	590	571
26	489.9	332.4	592.9	35	1.00	0.3667	26	36.7	39.0	593	580
27	342.9	7.6	224.8	21	1.25	0.1542	27	15.4	20.7	225	196
28	348.4	8.2	203.3	21	1.25	0.1948	28	19.5	22.8	203	191
29	444.9	13.9	194.7	21	1.25	0.3605	29	36.0	37.0	195	195
30	594.4	23.8	213.9	21	1.25	0.5640	30	56.4	56.7	214	213
31	305.0	14.6	270.9	25	1.25	0.1797	31	18.0	23.0	271	237
32	307.9	15.5	267.5	25	1.25	0.1931	32	19.3	25.0	268	231
33	485.7	34.3	320.6	25	1.25	0.3551	33	35.5	45.1	321	275
34	486.1	33.8	320.6	25	1.25	0.3515	34	35.2	44.0	321	278
35	588.4	47.8	287.0	25	1.25	0.6044	35	60.4	57.4	287	298
36	597.5	48.8	283.8	25	1.25	0.6297	36	63.0	58.0	284	301
37	320.3	32.2	407.0	29	1.25	0.1815	37	18.2	29.4	407	390
38	304.4	29.5	392.7	29	1.25	0.1737	38	17.4	27.6	393	294
39	514.4	67.2	403.5	29	1.25	0.4307	39	43.1	46.7	404	385
40	514.3	69.4	397.9	29	1.25	0.4497	40	45.0	49.2	398	376
41	576.5	91.7	400.2	29	1.25	0.5887	41	58.9	64.9	400	372
42	577.5	91.3	401.7	29	1.25	0.5845	42	58.5	64.2	402	374
43	703.3	128.6	400.9	29	1.25	0.8555	43	85.5	82.3	401	406
44	710.2	129.9	398.1	29	1.25	0.8759	44	87.6	82.4	398	410
45	344.1	68.1	614.9	35	1.25	0.1780	45	17.8	26.0	615	495
46	348.8	68.4	614.0	35	1.25	0.1805	46	18.1	25.6	614	504
47	522.4	165.6	590.7	35	1.25	0.4785	47	47.9	57.5	591	519
48	518.7	168.4	591.1	35	1.25	0.4813	48	48.1	59.8	591	507
49	574.3	206.7	599.5	35	1.25	0.5853	49	58.5	71.1	600	518
50	575.3	207.2	597.1	35	1.25	0.5904	50	59.0	71.2	597	519
51	689.0	272.3	608.3	35	1.25	0.7903	51	79.0	83.5	608	576
52	690.2	272.1	609.9	35	1.25	0.7880	52	78.8	83.1	610	578
53	376.1	96.9	691.8	38	1.25	0.2059	53	20.6	23.4	692	665
54	372.1	95.9	693.0	38	1.25	0.2024	54	20.2	23.4	693	659
55	503.1	200.1	700.0	38	1.25	0.4173	55	41.7	48.2	700	638
56	499.0	195.4	701.2	38	1.25	0.4069	56	40.7	47.0	701	640
57	576.3	276.3	701.9	38	1.25	0.5748	57	57.5	65.7	702	635
58	578.3	275.2	702.0	38	1.25	0.5741	58	57.4	65.0	702	640
59	657.2	356.3	696.3	38	1.25	0.7602	59	76.0	80.7	696	658
60	659.6	355.6	697.8	38	1.25	0.7590	60	75.9	80.0	698	663
61	330.2	160.4	795.8	44	1.25	0.2241	61	22.4	24.6	796	769
62	331.7	162.5	798.3	44	1.25	0.2258	62	22.6	25.0	798	768
63	428.6	288.9	792.2	44	1.25	0.4068	63	40.7	42.5	792	775
64	430.1	290.8	797.8	44	1.25	0.4054	64	40.5	42.7	798	776
65	513.4	418.9	797.2	44	1.25	0.5875	65	58.8	58.3	797	802
66	520.4	428.0	796.7	44	1.25	0.6025	66	60.3	59.1	797	808
67	507.9	6.2	196.1	21	1.50	0.4195	67	41.9	35.6	196	225
68	413.4	9.3	319.1	25	1.50	0.2407	68	24.1	30.5	319	280
69	484.5	12.8	316.1	25	1.50	0.3430	69	34.3	40.2	316	289
70	491.4	13.4	291.5	25	1.50	0.4032	70	40.3	42.3	292	286
71	637.9	21.5	325.9	25	1.50	0.5790	71	57.9	60.9	326	314
72	695.8	27.0	320.1	25	1.50	0.7414	72	74.1	77.1	320	308
73	701.5	26.6	319.9	25	1.50	0.7386	73	73.9	74.2	320	315
74	329.9	13.0	390.9	30	1.50	0.1979	74	19.8	22.7	391	371
75	329.9	12.8	404.8	30	1.50	0.1830	75	18.3	22.8	405	364
76	511.5	26.7	422.1	30	1.50	0.3992	76	39.9	37.1	422	454
77	500.8	26.1	425.8	30	1.50	0.3821	77	38.2	37.0	426	446
78	384.0	22.3	486.5	32	1.50	0.2351	78	23.5	28.4	487	442
79	388.6	22.6	482.7	32	1.50	0.2422	79	24.2	28.5	483	446
80	520.0	38.8	498.5	32	1.50	0.4158	80	41.6	43.7	499	488
81	519.5	39.5	498.3	32	1.50	0.4212	81	42.1	45.1	498	481
82	613.0	56.8	502.4	32	1.50	0.6058	82	60.6	62.9	502	487
83	606.6	57.3	502.4	32	1.50	0.6051	83	60.5	64.9	502	476
84	712.5	78.1	491.2	32	1.50	0.8686	84	86.9	83.5	491	498
85	703.5	77.1	497.0	32	1.50	0.8393	85	83.9	83.4	497	492
86	378.4	25.1	603.6	35	1.50	0.1821	86	18.2	19.5	604	615
87	374.4	24.7	603.5	35	1.50	0.1786	87	17.9	19.4	604	611
88	550.0	55.5	600.5	35	1.50	0.4276	88	42.8	39.9	601	643
89	548.2	59.9	610.4	35	1.50	0.4402	89	44.0	45.4	610	605
90	633.2	85.3	595.1	35	1.50	0.6494	90	64.9	64.5	595	595
91	610.1	77.0	609.5	35	1.50	0.5690	91	56.9	57.8	610	602
92	702.7	102.3	607.9	35	1.50	0.7704	92	77.0	73.6	608	621
93	701.0	102.4	607.6	35	1.50	0.7701	93	77.0	74.0	608	618
94	379.2	34.1	698.8	38	1.50	0.1842	94	18.4	18.7	699	740
95	377.6	34.2	699.9	38	1.50	0.1836	95	18.4	19.0	700	734
96	480.4	64.0	698.7	38	1.50	0.3458	96	34.6	36.3	699	693
97	496.8	67.6	698.1	38	1.50	0.3688	97	36.9	37.6	698	705
98	510.0	71.7	693.4	38	1.50	0.3959	98	39.6	39.7	693	705
99	611.1	119.0	697.8	38	1.50	0.6387	99	63.9	68.4	698	660
100	609.7	118.9	702.6	38	1.50	0.6312	100	63.1	68.5	693	659
101	659.2	147.7	693.8	38	1.50	0.7979	101	79.8	84.3	694	657
102	668.3	148.8	694.0	38	1.50	0.8009	102	80.1	85.5	694	652
103	330.0	54.6	802.7	44	1.50	0.1965	103	19.6	19.2	803	860
104	328.6	53.9	803.7	44	1.50	0.1936	104	19.4	18.9	804	862
105	429.3	107.7	793.9	44	1.50	0.3893	105	38.9	38.5	794	811
106	430.1	108.7	795.8	44	1.50	0.3910	106	39.1	39.0	796	808
107	511.8	165.2	802.7	44	1.50	0.5810	107	58.1	58.7	803	797
108	513.4	167.7	802.4	44	1.50	0.5887	108	58.9	59.9	802	792
109	538.0	189.7	783.6	44	1.50	0.6848	109	68.5	68.0	784	784
110	538.5	189.7	784.6	44	1.50	0.6836					




Fig. 1—Plan and elevation views of the orifice/choke meter run.




Fig. 2—Comparison of measured and predicted steam quality for 1.00-in. orifice plate.




Fig. 3—Comparison of measured and predicted steam quality for 1.25-in. orifice plate.




Fig. 4—Comparison of measured and predicted steam quality for 1.50-in. orifice plate.




Fig. 5—Comparison of measured and predicted flowrate for 1.00-in. orifice plate.




Fig. 6—Comparison of measured and predicted flowrate for 1.25-in. orifice plate.




Fig. 7—Comparison of measured and predicted flowrate for 1.50-in. orifice plate.




Fig. 8—General pressure, flowrate, and steam quality curve for orifice choke device.